

Dhaka Power Distribution Company Ltd.
Network Operation & Customer Service, Postogola

Load Shedding on 11 KV Feeder

Allocation of Dhaka City : 1100 MW

Allocation of Postogola S/S : 11.64 MW, Evening- 10.82 MW

Feeder Name & User NOCS	Area Under the Feeders	Load Shedding Period												
			18:00-19:00	19:00-20:00	20:00-21:00	21:00-22:00	22:00-23:00	23:00-24:00	24:00-01:00	01:00-02:00	02:00-03:00	03:00-04:00	04:00-05:00	05:00-06:00
K. Ali Feeder NOCS, Jurain	Commissioner Road, K. Ali Road, Bagan Bari, Sksumbag, East Jurain.	*	5.00	5.30	5.30	5.50	5.40	5.20	5.10	5.10	4.18	4.00	4.00	3.50
Farashgonj NOCS, Banglabazar	Sutrapur Thana Campas, Sutrapur Bazar, Part of R.S. Das Road, Tanugonj Lane & Khaterpul Lane	*	1.28	1.30	1.33	1.34	1.33	1.20	1.00	0.90	0.91	0.92	0.82	0.72
Postogola-2 (Habib) NOCS, Postogola	Tula Bagicha, Jurain Grave Jard, B.B Colony, Jurain Chairman Bari, Part of Karimullarbag.	*	1.92	2.00	2.10	2.10	2.07	2.00	2.00	1.72	1.60	1.50	1.32	1.20
Mazar NOCS, Postogola	West Jurain high bari, Part of Karimullarbag, Postogola Railway Market, Bjoliapar, Postogola NOCS, West Jurain, Mir Hazaribag.	*	4.90	4.80	4.80	4.62	4.50	4.25	4.00	4.00	4.00	3.95	3.92	3.95
Sumon & Sons. NOCS, Jurain	Satu Market, Part of Jurain	*	1.90	2.20	2.23	2.00	1.90	1.50	1.00	1.00	1.00	1.00	1.00	1.00
Alambagh Express NOCS, Jurain	Alambagh, Steel Mill	*	0.16	0.16	0.16	1.60	0.16	1.20	1.50	1.70	1.90	2.50	2.80	3.30
Postogola Local NOCS, Postogola	Postogola Control Room, Postogola Staff Quarter.	*	0.16	0.16	0.16	0.16	0.16	0.12	0.12	0.12	0.12	0.12	0.12	0.12
Postogola-1 (Saika) NOCS, Postogola	Razabari, Karimullarbag Mollah Bari, Bazargoli, Arshin Gate.	*	4.50	5.00	5.00	5.00	5.00	4.60	4.20	3.80	3.90	3.90	3.91	3.80
Loharpool	Millbarak water pump.	*	2.20	2.50	2.35	2.36	2.25	1.90	1.92	1.80	1.90	1.60	1.60	1.60

NOCS, Postogola	Bholaikhal water pump, Alamgonj Road, Faridabad Lane, Nabin Chandro Goshami Raod, Horicharon Ray Road, Bahadur Pur Lane, Dhalka Nagor Lane, Boishaky Housing, S.K Das Road, Kalicharon Road, K.B Road.													
Postogola Cant.	Postogola Cantonment, Shaympur Thana.	*	0.50	0.50	0.50	0.50	0.50	0.45	0.45	0.45	0.45	0.45	0.45	0.45
NOCS, Postogola														
Razabari	Postogola, Razabari.	*	0.16	0.16	0.16	0.16	0.16	1.50	1.80	2.50	2.70	3.00	3.00	2.80
NOCS, Postogola														
Total =				22.68	24.08	24.09	25.34	23.43	23.92	23.09	23.09	22.66	22.94	22.94

Legend : * Load (MW)  Load Shedding